

June 3, 2008

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: SEPTIC, PUMP, GREASE INTERCEPTOR OR HOLDING
Model Number(s): 1200
(47.0" L.L., 28.66 GAL/IN., 48" MAX. DEPTH OF BURY, 645 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20080279

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with an access opening above each inlet.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Low end and side pipe openings for pump, siphon and holding tanks.
 - Top inlet opening for holding, pump, or siphon tanks.
 - Six inch inlet and outlet openings.
 - ADS N-12 Prolink Pipe as a manhole riser and cover using an ADS coupler to join manhole riser sections together.
 - Press Seal "Cast-A-Seal" gaskets.

LAKE SHORE BURIAL VAULT CO., INC.

Page 2

June 3, 2008

PRODUCT FILE NO. 20080279

- Installation of UV disinfection unit Model "The Disinfector" manufactured by UV "The Disinfector" Inc., installed in accordance with the product approval for the UV disinfection unit.

This approval supersedes the approval issued on 10/15/2007 under product file number 20070446.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070446.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov